

## Christina Smits

---

**From:** Murray England <Murray.England@selwyn.govt.nz>  
**Sent:** Friday, 30 July 2021 8:07 am  
**To:** Alice Burnett; Daniel Meehan  
**Cc:** Jamie Verstappen  
**Subject:** RE: Hughes Developments - Stormwater Discharges

Hi Alice,

Yes, that is our understanding. This is common practice in Rolleston.

Kind regards

Murray England  
Asset Manager – Water Services

---

**From:** Alice Burnett [mailto:[alice.burnett@dls.co.nz](mailto:alice.burnett@dls.co.nz)]  
**Sent:** Friday, 30 July 2021 8:00 AM  
**To:** Daniel Meehan <[Daniel.Meehan@selwyn.govt.nz](mailto:Daniel.Meehan@selwyn.govt.nz)>; Murray England <[Murray.England@selwyn.govt.nz](mailto:Murray.England@selwyn.govt.nz)>  
**Cc:** Jamie Verstappen <[Jamie.Verstappen@dls.co.nz](mailto:Jamie.Verstappen@dls.co.nz)>  
**Subject:** Hughes Developments - Stormwater Discharges

Hi Daniel and Murray,

We are assisting Hughes Developments with a Fast Track resource consent to enable residential development in Rolleston which is being processed via the Environmental Protection Agency. The two sites to which this application relates to are known as Faringdon South East and South West, location shown below.



As part of the application process we have received comments from Environment Canterbury. One of the comments made is in relation to stormwater discharges from roof stormwater on each individual lot. In our application we have said that roof stormwater will be discharged to individual soakpits within each of the lots. It is our understanding that these soakpits are maintained by the lot owner and are not the responsibility of Selwyn District Council and as such does not form part of the reticulated stormwater system for Rolleston. It is also our understanding that it is Selwyn's preference for stormwater from roofs are discharged in this manner.

Can you please confirm this understanding is correct.

Kind regards

**Alice Burnett**  
Planner

  
DAWIE LOVELL-SMITH  
Planning Surveying Engineering  
PO Box 679 | Christchurch | Phone: 027 711 0603 | Telephone: (03) 379 0793 [www.dls.co.nz](http://www.dls.co.nz)

*Confidentiality: The information contained in this email message may be legally privileged and confidential. If the reader of this message is not the intended recipient, please notify us immediately and destroy the original.*



2 Norman Kirk Drive, Rolleston 7614  
PO Box 90, Rolleston 7643  
Phone: 0800 SELWYN (735 996)  
Fax: (03) 347-2799  
[www.selwyn.govt.nz](http://www.selwyn.govt.nz) | [www.selwynlibraries.co.nz](http://www.selwynlibraries.co.nz)  
[www.selwyn.getsready.net](http://www.selwyn.getsready.net)